

WA 2917 42
8/19/1987

WEEKLY TANK INSPECTION REPORT

The following tanks were inspected for corrosion, leaking valves, seams or manholes.

C. # OK NEEDS REPAIR

30	✓	
31		
32		
33		
34	✓	
35		PNO
36	✓	
37	✓	
38	✓	
39	✓	
00	✓	
01		
02		
03		
04		

TANK # OK NEEDS REPAIR

105	✓	
106	✓	
107	✓	Leaky Coils
108	✓	
109	✓	
110	✓	Coils Leak Boom Broken Boom
111	✓	
112	✓	
113		PNO
114	✓	
115	✓	
116	✓	
117	✓	
118	✓	
165	✓	

FILE COPY

11 tank yard berms OK ☒ NEEDS REPAIR

SEL YARD berms OK ☒ NEEDS REPAIR

yard berms OK ☒ NEEDS REPAIR

ADDITIONAL COMMENTS Indicated Leaky Coils in PNO. Incorrect was just rusty condensate. AOA

Reported for the week of 8-19 1987

Signed Nate Mathews

USEPA RCRA



3012727